

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7272-0028:0510  
**CATEGORY:** 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

Page 1 of 1

**LISTEE:** NotifierOne Fire-Lite Place, Northford, CT 06472-1653  
Contact: Pete Sennett (203) 484-6127 Fax (203) 484-7309  
Email: pete.sennett@honeywell.com

**DESIGN:** Models FCO-951, FCO-951-IV, FCO-951-ISO, photoelectric smoke detector with complementary heat detector, complementary electrochemical carbon monoxide (CO) detector, and supplemental infrared flame sensor, analog addressable.

Models FPTI-951, FPTI-951-IV, photoelectric smoke detector with complementary heat detector, and supplemental infrared flame sensor, analog addressable.

Models FPC-951, NP-200C, photoelectric smoke detector with complementary electrochemical carbon monoxide (CO) detector, analog addressable.

Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as photoelectric smoke detector with complementary heat detector, complementary electrochemical carbon monoxide (CO) detector, and supplemental infrared flame sensor for use with System Sensor (S911) - Models B200S, B200S-WH, B200S-IV, B200SR, B200SR-WH, B200SR-IV, (CSFM Listing 7300-1653:0213) B200SR-LF, B200SR-LF-WH, B200SR-LF-IV, (CSFM Listing 7300-1653:0238), B210LP, B300-6, B300-6-IV, B300-6-IS, B300-6-IS-W, B300-6-IS-IV, B501, B501-WHITE, B501-IV, B501-BL, (CSFM Listing 7300-1653:0109) B224BI, B224BI-WH, B224BI-IV, B224RB, B224RB-WH, B224RB-IV, (CSFM Listing 7300-1653:0126).  
Silent Knight (S6173) - Model IDP-6AB (CSFM Listing 7300-0559:0159).  
Fire-Lite (S1059) - Model B350LP (CSFM Listing 7300-0075:0192).

04-15-2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **April 18, 2019**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*