

JMPE

ELECTRICAL ENGINEERING
LIGHTING DESIGN
CA REGISTRATION NO E13083

PRE-BID MEETING

PROJECT: Goleta USD Fire Alarm Upgrades
Kellogg, Foothill & Hollister Schools

DATE: Monday, June 3, 2019 TIME: 0900-1130

PRESENT: See sign-in sheet

NOTES:

1. Anytime the fire alarm system is not active, a Fire Watch is required.
2. Conduits have all been verified on site. Where existing conduits are shown to be re-used, the old cables were able to move when tested.
3. At Hollister School, Portable #23 behind the County building will need to have a new 1" conduit run from the flush pullbox to the building. The existing conduit is broken.
4. At Hollister School, the existing com/data route through the parking lot is broken. Plans show an alternate route. Follow this alternate route.
5. See additional notes from Justina.

627 OLIVE STREET
SANTA BARBARA, CA 93101
(805)569.9216
maloney@jmpe.net
www.jmpe.net

