



# LA Testing

520 Mission Street South Pasadena, CA 91030  
Tel/Fax: (323) 254-9960 / (323) 254-9982  
<http://www.LATesting.com> / [pasadenalab@latesting.com](mailto:pasadenalab@latesting.com)

**LA Testing Order:** 322010302  
**Customer ID:** DEVR72  
**Customer PO:**  
**Project ID:**

**Attention:** Insight Environmental Inc.  
1180 Eugenia Place  
Carpinteria, CA 93013


**Phone:** (805) 898-1123  
**Fax:** (805) 569-6466  
**Received Date:** 06/09/2020 8:55 AM  
**Analysis Date:** 06/09/2020  
**Collected Date:** 06/08/2020

**Project:** 7421 Mirano Dr. (Goleta Union School Dist)

## Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
1 322010302-0001	Front office hallway - Acoustic	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
2 322010302-0002	Outside men's restroom - Acoustic	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
3 322010302-0003	Supply cubicle room - Acoustic	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
4 322010302-0004	Wood shop area - Acoustic	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
5 322010302-0005	Library - Acoustic	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected

Analyst(s)  
Olivia Santiago (2)  
Tania Lopez (3)

  
Jerry Drapala Ph.D, Laboratory Manager  
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method"), but augmented with procedures outlined in the 1993 ("final") version of the method. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. All samples received in acceptable condition unless otherwise noted. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. EMSL recommends gravimetric reduction for all non-friable organically bound materials prior to analysis. Estimation of uncertainty is available on request.

Samples analyzed by LA Testing South Pasadena, CA NVLAP Lab Code 200232-0, CA ELAP 2283

Initial report from: 06/09/2020 10:29:15